



CITY OF GLENDALE

LIQUIFIED PETROLEUM GAS REQUIREMENTS

1. A Fire Department permit is not required to install or maintain portable containers of less than 125 gallons aggregate water capacity. (Exception UFC 8202.1)
 - * Any tank exceeding 125 gallon aggregate water capacity requires review by the Fire Department and has a review time of 3 working days.
2. Tanks shall be accessible for inspection. (Uniform Plumbing Code Section 1213.3).
3. All exposed gas piping shall be kept at least 6 inches above-grade and secured. (Uniform Plumbing Code Section 1211.3 and 1211.8)
4. All tanks require a shut-off control valve. (Uniform Plumbing Code Section 1211.9)
5. Distances:
 - 10 feet from any electrical unless electrical is explosion proof
 - 10 feet from any source of open flame or ignition
 - 5 feet from any opening into the home or structure
 - 5 feet from the property line. **Exception:** Block fence walls may act as a vapor barrier
6. Anchor tanks with a chain or strap.
7. Tanks must be installed on a non-combustible base (2-inch concrete) (Uniform Plumbing Code 1211.14) with 30 inches of working space and platform. (Uniform Fire Code)
 - * We do recognize manufacture installation requirements for appliances.

PERMIT FEE - \$25.00

Note: Liquified petroleum gas shall not serve any appliance located in a pit or basement where gas that is heavier than air might collect to form a flammable mixture. (Uniform Mechanical Code and Uniform Plumbing Code)